

DETECT-A-FIRE® APPROVALS & LISTINGS UL CERTIFICATE NO. E89599
Heat Actuated Devices for Use in Hazardous Locations



Underwriters Laboratories Inc.®

UIPV **May 22, 1992**
Heat Actuated Devices For Special Application For Use in Hazardous Locations

KIDDE-FENWAL INC , ASHLAND MA 01721

E89599 (N)

**Class I, Groups A, B, C and D, Class II,
Groups E, F and G.**

Rate compensation type heat detectors intended for equipment protection applications, Models 27121-000, 27121-020, 28021-000 and 28021-005 all rated 600 F and 725 F.

400 MAIN ST

LOOK FOR LISTING MARK ON PRODUCT

**Replaces E89599 Dated May 23, 1991, Filed FENWAL INC
359696001 Underwriters Laboratories Inc.®**

**G11/0103786
242**