

DETECT-A-FIRE® APPROVALS & LISTINGS UL CERTIFICATE NO. E19310
Automatic Fire Detector for Use in Hazardous Locations



Underwriters Laboratories Inc.®

UIRV **May 22, 1992**
Heat-Automatic Fire Detectors For Use in Hazardous Locations

KIDDE-FENWAL INC , ASHLAND MA 01721

E19310 (N)
(A card)

Class I, Groups A, B, C and D; Class II, Groups E, F and G.

Type Detector	Type No.	Temp. Range Deg F	Spacing - Ft	
			Smooth Ceiling	To Wall or Partition
Rate compensation	27121-000	*	50	25
Rate compensation	27121-000	**	25	12.5
Rate compensation	27121-020	*	50	25
Rate compensation	27121-020	**	25	12.5
Rate compensation	28021-000	*	50	25
Rate compensation	28021-000	**	25	12.5
Rate compensation	28021-005	*	50	25
Rate compensation	28021-005	**	25	12.5

*-140-144, 175-194, 250-269, 325-344, 400-424.

** -145-164, 195-234, 270-309, 345-384, 425-474.

Replaces E19310 Dated March 26, 1991, Filed FENWAL INC (Cont. on B card)
 359696001 H0821 **Underwriters Laboratories Inc.®** G11/0057017
 243